

Den Braven Romania Comex SRL
51, Rasaritului St. (DN7)
070000 Buftea, IF
ROMANIA

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

VOC@eurofins.com
www.eurofins.com/VOC-testing

VOC TEST REPORT


Indoor Air Comfort GOLD[®]

17 January 2017

1 Sample Information

Sample name	1K PU FOAM HH B3 SUMMER DIY
Batch no.	29597
Production date	24/11/2016
Product type	Foam
Sample reception	09/12/2016


2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Regulation of March and April 2011 (DEVL1101903D and DEVL1104875A)
French CMR components	Pass	Regulation of March and April 2011 (DEVL1101903D and DEVL1104875A)
AgBB	Pass	AgBB of February 2015. DIBt of October 2010
Belgian Regulation	Pass	Royal decree of May 2015 (C-2014/24239)
Indoor Air Comfort [®]	Pass	Indoor Air Comfort 5.3a of March 2015
Indoor Air Comfort GOLD [®]	Pass	Indoor Air Comfort GOLD 5.3a of March 2015
EMICODE	EC 1 PLUS	November 2015
EN 717-1 [§]	E1	2004
Blue Angel (RAL UZ 132)	Pass	Low-Emission Thermal Insulation Material and Suspended Ceilings for Use in Buildings, October 2010
BREEAM International	Compliant	GN22: BREEAM Recognised Schemes for VOC Emissions from Building Products
LEED v4 (outside U.S.)	Compliant	LEED v4 for Building Design and Construction (April, 2015)

Full details based on the testing and direct comparison with limit values is available in the following pages



Maria Pelle
Chemist



Janne R. Norup
Chemist

The results are only valid for the tested sample(s).

This report may only be copied or reprinted in its entity, parts of it only with a written acceptance by Eurofins.